

March 6, 2002

Mr. Richard J. Payonk  
Wabash River Energy Ltd.  
444 West Sanford Avenue  
West Terre Haute, Indiana 47885

Re: R 167-13520-00091  
First Reopening to Part 70 Operating  
Permit  
T 167-7353-00091

Dear Mr. Payonk:

Wabash River Energy Ltd., was issued a Part 70 Operating Permit on December 31, 1998. The Office of Air Quality (OAQ) has determined that it is necessary to reopen your Part 70 permit. Notice of the permit reopening pursuant to 326 IAC 2-7-9(c) was provided on August 16, 2000.

As stated in the Notice, the language in 40 CFR Part 70.6(c)(5)(iii)(B)) was changed from "continuous or intermittent compliance" to "based on continuous or intermittent data" as part of the U.S. EPA's 1997 Compliance Assurance Monitoring rule making (Federal Register Volume 62, page 54900-54947, Wednesday, October 22, 1997). The U.S. District Court of Appeals, Washington D.C. ruled against EPA's language, saying that the Clean Air Act wording of continuous or intermittent compliance had to be used. (NRDC vs. EPA, #97-1727) Therefore, the following change is being made to your permit to be consistent with state and federal law.

Condition B.11(c)(3) is revised as follows:

---

B.11 Annual Compliance Certification [326 IAC 2-7-6(5)]

---

- (c) The annual compliance certification report shall include the following:
- (1) The appropriate identification of each term or condition of this permit that is the basis of the certification;
  - (2) The compliance status;
  - (3) Whether compliance was ~~based on~~ continuous or intermittent data;
  - (4) The methods used for determining compliance of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3); and
  - (5) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ, may require to determine the compliance status of the source.

Wabash River Energy Ltd.  
West Terre Haute, Indiana  
Reviewer: Gary Freeman

Page 2 of 2  
Reopening No. R 167-13520-00091  
Part 70 Permit No. T 167-7353-00091

All other conditions of the permit shall remain unchanged and in effect. Please attach a copy of this reopening and the following revised permit pages to the front of the original permit.

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5. If you have any questions on this matter, please contact Stacey Pfeffer, at (800) 451-6027, press 0 and ask for Stacey Pfeffer or extension 3-2628, or dial (317) 233-2628.

Sincerely,

Original signed by

Paul Dubenetzky, Chief  
Permits Branch  
Office of Air Quality

Attachments

SP/gkf

cc: File Vigo County  
Vigo County Health Department  
Air Compliance Section Inspector - Jim Thorpe  
Compliance Data Section - Karen Nowak  
Administrative and Development File  
Technical Support and Modeling - Michele Boner

**PART 70 OPERATING PERMIT  
OFFICE OF AIR QUALITY  
and  
VIGO COUNTY AIR POLLUTION CONTROL**

**Wabash River Energy Ltd.  
444 West Sandford Avenue  
West Terre Haute, Indiana 47885**

(herein known as the Permittee) is hereby authorized to operate subject to the conditions contained herein, the source described in Section A (Source Summary) of this permit.

This permit is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 and 326 IAC 2-1-3.2 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Operation Permit No.: T167-7353-00091	
Issued by: Janet G. McCabe, Assistant Commissioner Office of Air Quality	Issuance Date: December 31, 1998  Expiration Date: December 31, 2003

First Administrative Amendment 167-11851-00091, issued March 1, 2000

Second Administrative Amendment 167-12145-00091, issued August 31, 2000

First Reopening: R 167-13520-00091	Page Affected: 10
Issued by: Original signed by Paul Dubenetzky, Branch Chief Office of Air Quality	Issuance Date: March 6, 2002

- (c) The annual compliance certification report shall include the following:
- (1) The identification of each term or condition of this permit that is the basis of the certification;
  - (2) The compliance status;
  - (3) Whether compliance was continuous or intermittent;
  - (4) The methods used for determining compliance of the source, currently and over the reporting period consistent with 326 IAC 2-7-5(3);
  - (5) Any insignificant activity that has been added without a permit revision; and
  - (6) Such other facts, as specified in Sections D of this permit, as IDEM, OAQ and VCAPC, may require to determine the compliance status of the source.

The submittal by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

B.12 Preventive Maintenance Plan [326 IAC 2-7-5(1),(3) and (13)] [326 IAC 2-7-6(1) and (6)]  
[326 IAC 1-6-3]

---

- (a) If required by specific condition(s) in Section D of this permit, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMP) within ninety (90) days after issuance of this permit, including the following information on each:
- (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission units and associated emission control devices;
  - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions;
  - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If due to circumstances beyond its control, the PMP cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management  
Compliance Branch, Office of Air Quality  
100 North Senate Avenue, P.O. Box 6015  
Indianapolis, Indiana 46206-6015

and

Vigo County Air Pollution Control  
201 Cherry Street  
Terre Haute, Indiana 47807